

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HOLIDAY INN EXPRESS WELLS OGUNQUIT KENNEBUNKPORT (	REGULAR	2021-11-04	No		No Violations	
HOLIDAY INN EXPRESS WELLS OGUNQUIT KENNEBUNKPORT (	REGULAR	2023-12-20	No	6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				3.G.2	Appropriate test kit, DPD or FAS-DPD not provided, test kit not capable of testing for free and combined chlorine, pH, total alkalinity, calcium hardness and when used, cyanuric acid, reagents are over one year old and/or prohibited OTO kits and/or test strips are being used.	C