

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
DEANS LANDING	REGULAR	2018-08-01	No		No Violations	
DEANS LANDING	REGULAR	2018-08-01	No	2.B	Register does not contain required signature and information.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
DEANS LANDING	REGULAR	2020-09-02	No	3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				6.C	Openings to the outside are not effectively protected against the entrance of rodents.	
DEANS LANDING	NEWOWNER	2023-04-10	No	5-203.13	Inadequate number of service sinks.	N
				6-202.112	Lodging or sleeping quarters not separated from food operations.	N
DEANS LANDING	NEWOWNER	2023-04-10	No	3.F.1	Inadequate number of facilities provided.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				6.B	Openings to the outer air are not effectively protected against the entrance of flies and other flying insects by the use of self-closing doors, closed windows and screening.	
DEANS LANDING	FOLLOW_UP_FULL	2023-05-08	No		No Violations	
DEANS LANDING	FOLLOW_UP_FULL	2023-05-08	No		No Violations	