

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MEDWAY MIDDLE SCHOOL	REGULAR	2018-10-10	No	4-302.14	No chemical test kit available.	N
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
MEDWAY MIDDLE SCHOOL	REGULAR	2019-10-21	No	4-302.14	No chemical test kit available.	N
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
				6-201.11	Floors, walls, and ceilings are not smooth and easily cleanable.	N
MEDWAY MIDDLE SCHOOL	REGULAR	2021-01-28	No	4-204.115	Ware washing machine not properly equipped with temperature measuring devices.	N
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
MEDWAY MIDDLE SCHOOL	REGULAR	2021-12-07	No	4-501.11	Equipment in disrepair.	N
				5-202.13	Air gap required.	C
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
MEDWAY MIDDLE SCHOOL	REGULAR	2022-09-27	No	4-501.11	Equipment in disrepair.	N
				5-202.13	Air gap required.	C
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
MEDWAY MIDDLE SCHOOL	REGULAR	2023-10-20	No	4-302.14	No chemical test kit available.	N
				5-202.13	Air gap required.	C
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
				6-201.11	Floors, walls, and ceilings are not smooth and easily cleanable.	N