

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CHRISTIES CAMPGROUND & COTTAGES	REGULAR	2019-06-24	No		No Violations	
CHRISTIES CAMPGROUND & COTTAGES	REGULAR	2019-06-24	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	