Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MARGARET CHASE SMITH COMMUNITY SCHOOL	REGULAR	2025-11-07	No	5-202.12	Hand washing facility not properly equipped/installed with hot water of at least 100 F.	N
				6-202.14	Toilet room not enclosed, with a self closing, tight fitting door.	N