Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MARTIN STREAM CAMGROUND	REGULAR	2026-06-08	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.2	Depth markers are not properly positioned to be read from the water side on a vertical pool wall.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diamenter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diamenter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C
MARTIN STREAM CAMGROUND	REGULAR	2026-06-08	No	5.B.1	Pool data sheet not posted and/or does not contain required information.	N
				3.G.1	Sanitizer residual and pH not recorded three times a day, one manual test not conducted, proper records of maintenance and chemicals added not maintained and/or recorded once per day, total alkalinity, calcium hardness, and cyanuric acid (if used) not being tested for and recorded once per week, water chemistry records not retained for 1 year and/or the water chemistry records not available.	C
				6.C.2	Depth markers are not properly positioned to be read from the water side on a vertical pool wall.	C
				6.D.3	Ring buoy with throwing rope attached not provided, ring buoy is not US Coast Guard-approved with an outside diamenter of 15 inches or greater, throwing rope for the ring buoy not of a minimum 1/4 inch diamenter and/or throwing rope of ring buoy is not long enough (1.5 x width of pool) or 50 feet, whichever is less.	C