

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ALLAGASH GATEWAY CAMPGROUND & CABINS	REGULAR	2019-09-17	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				9.A	Privies are not constructed to be fly tight and/or properly ventilated.	
ALLAGASH GATEWAY CAMPGROUND & CABINS	REGULAR	2023-08-31	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				6.B	Openings to the outer air are not effectively protected against the entrance of flies and other flying insects by the use of self-closing doors, closed windows and screening.	