

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MARSHALL HOTEL	REGULAR	2019-11-20	No	11-A.(2)	Screening material is not less than 16 mesh to the inch or equivalent.	N
				9-A.(2)	Clean linens and supplies are not properly stored in cabinets constructed to facilitate cleaning, on shelves at least 6 inches off the floor and/or in storage rooms that are kept clean.	N
				9-A.(6)	No Material Safety Data Sheet available on the premises.	N
				9-A.(3)	Soiled linen not properly handled or stored so as to not contact clean linen.	N
				9-A.(1)	Storage rooms or cabinets are not provided for all supplies, linens, and equipment.	N
				4-A.(1)	Establishment is not in compliance with NFPA 101 Life Safety Code.	C