

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited   | Description of Violation  | Severity |
|--------------------|------------|------------|-------|--------------|---|----------|
| MAYNARDS-IN-MAINE  | REGULAR    | 2018-05-17 | No    | 5-202.12     | Hand washing facility not properly equipped/installed with hot water of at least 100 F.   | N        |
|                    |            |            |       | 3-603.11.(A) | There is no consumer advisory.  | C        |
|                    |            |            |       | 3-305.11     | Food not protected from contamination during storage.   | N        |
|                    |            |            |       | 5-203.13     | Inadequate number of service sinks.   | N        |
|                    |            |            |       | 5-203.14     | Backflow prevention device not installed when required.   | C        |
|                    |            |            |       | 6-201.18     | Studs, joists, and rafters are exposed in areas subject to moisture.  | N        |
| MAYNARDS-IN-MAINE  | REGULAR    | 2018-05-17 | No    | 2-C.(7)      | Toilet facilities, including the toilet room and fixtures, are not properly maintained, clean, adequately vented, and/or free of objectionable odors. | N        |
| MAYNARDS-IN-MAINE  | REGULAR    | 2020-07-08 | No    |              | No Violations   |          |