

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HIDDEN VALLEY CAMP	REGULAR	2021-07-15	No		No Violations	
HIDDEN VALLEY CAMP	REGULAR	2022-07-20	No	7.D.1.c	C: All self-watering water troughs without an air gap are not equipped with backflow prevention.	C
HIDDEN VALLEY CAMP	REGULAR	2022-07-20	No	6.C.1	Depth markers not present, not conspicuously marked at or above the waterline, on the vertical pool wall, and/or on top of the coping, or on the edge of the deck or on the walk next to the pool.	C
				6.D.2	Not equipped with a light, strong pole not less than 12 feet long, including a body hook.	C