

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SEARSPORT HIGH/ MIDDLE SCHOOL	REGULAR	2018-01-10	No		No Violations	
SEARSPORT HIGH/ MIDDLE SCHOOL	REGULAR	2018-10-18	No		No Violations	
SEARSPORT HIGH/ MIDDLE SCHOOL	REGULAR	2019-10-24	No	5-202.13	Air gap required.	C
SEARSPORT HIGH/ MIDDLE SCHOOL	REGULAR	2022-02-01	No		No Violations	
SEARSPORT HIGH/ MIDDLE SCHOOL	REGULAR	2022-11-16	No		No Violations	
SEARSPORT HIGH/ MIDDLE SCHOOL	REGULAR	2023-10-18	No	5-205.15	Plumbing system not properly maintained in good repair.	C
				5-402.11	There is a direct connection between the sewage system and a drain originating from Equipment in which Food, portable equipment or Utensils are placed	C
				6-202.14	Toilet room not enclosed, with a self closing, tight fitting door.	N