

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PLEASANT LAKE CAMPING AREA	REGULAR	2019-06-27	No		No Violations	
PLEASANT LAKE CAMPING AREA	REGULAR	2019-06-27	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
PLEASANT LAKE CAMPING AREA	REGULAR	2021-09-24	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
PLEASANT LAKE CAMPING AREA	REGULAR	2023-07-21	No	6-202.14	Toilet room not enclosed, with a self closing, tight fitting door.	N
PLEASANT LAKE CAMPING AREA	REGULAR	2023-07-21	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	