

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|---------------------------|------------|------------|-------|------------|---|----------|
| LUBEC CONSOLIDATED SCHOOL | REGULAR | 2018-12-04 | No | | No Violations | |
| LUBEC CONSOLIDATED SCHOOL | REGULAR | 2019-11-13 | No | | No Violations | |
| LUBEC CONSOLIDATED SCHOOL | REGULAR | 2021-05-21 | No | 6-201.11 | Floors, walls, and ceilings are not smooth and easily cleanable. | N |
| LUBEC CONSOLIDATED SCHOOL | REGULAR | 2022-02-02 | No | 5-202.12 | Hand washing facility not properly equipped/installed with hot water of at least 100 F. | N |
| LUBEC CONSOLIDATED SCHOOL | REGULAR | 2022-11-14 | No | | No Violations | |
| LUBEC CONSOLIDATED SCHOOL | REGULAR | 2023-12-12 | No | | No Violations | |