

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HILLTOP CAMPGROUND	REGULAR	2019-07-31	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
HILLTOP CAMPGROUND	REGULAR	2021-09-22	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	