

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
THE VILLAGE CAMPS	REGULAR	2018-07-17	No	9-A.(8)	Lights are not shielded in the laundry areas and the linen storage facilities.	N
THE VILLAGE CAMPS	REGULAR	2021-08-19	No	10-A.(1).a	Guest register is incomplete.	N
				6-A.(7)	Establishments operating with private water supplies did not test and have water approved within the last twelve (12) months of operation, establishments operating seasonally with a private water supply did not test water prior to opening for the season and/or a copy of the water test results not available for inspection by the Department.	C
				4-A.(1)	Establishment is not in compliance with NFPA 101 Life Safety Code.	C
GRAND LAKE COTTAGES	NEWOWNER	2022-06-27	No		No Violations	
GRAND LAKE COTTAGES	NEWOWNER	2022-08-24	No	9-A.(6)	No Material Safety Data Sheet available on the premises.	N
				4-A.(1)	Establishment is not in compliance with NFPA 101 Life Safety Code.	C
				2-A.(12)	The lodging establishment failed to wash, rinse and sanitize the cooking and multi-use eating and drinking tableware prior to use by succeeding guests.	C