

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|--------------------|------------|------------|-------|------------|--|----------|
| THE PINES          | REGULAR    | 2019-08-30 | No    |            | No Violations  |          |
| THE PINES          | REGULAR    | 2019-08-30 | No    | 9-A.(8)    | Lights are not shielded in the laundry areas and the linen storage facilities. | N        |
| THE PINES          | REGULAR    | 2022-06-03 | No    | 6-201.11   | Floors, walls, and ceilings are not smooth and easily cleanable.               | N        |
| THE PINES          | REGULAR    | 2022-06-03 | No    | 4-A.(1)    | Establishment is not in compliance with NFPA 101 Life Safety Code.             | C        |