

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HOMESTEAD BY THE RIVER	REGULAR	2021-07-14	No		No Violations	
HOMESTEAD BY THE RIVER	REGULAR	2022-08-18	No	2.A	Register not kept as required.	
				3.C	Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	