

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HOLLIS ELEMENTARY SCHOOL	REGULAR	2018-09-27	No		No Violations	
HOLLIS ELEMENTARY SCHOOL	REGULAR	2019-09-30	No		No Violations	
HOLLIS ELEMENTARY SCHOOL	REGULAR	2022-04-26	No	6-501.11	The physical facilities are in disrepair.	N
HOLLIS ELEMENTARY SCHOOL	REGULAR	2023-11-02	No	6-201.12	Utility lines and pipes were installed unnecessarily exposed as to obstruct or prevent cleaning of floors, walls, or ceilings, or installed on the floor.	N
				6-201.13.(A)	Floor and wall junctures are not enclosed and sealed.	N
				6-501.11	The physical facilities are in disrepair.	N
				6-202.11	Lights not shielded.	N