

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
YANKEELAND CAMPGROUND	REGULAR	2019-05-06	No		No Violations	
YANKEELAND RV RESORT LLC	REGULAR	2020-05-28	No		No Violations	
YANKEELAND RV RESORT LLC	REGULAR	2023-06-26	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	