

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SKYDIVE NEW ENGLAND	REGULAR	2019-07-16	Yes	1.F	More sites than the approved number.	
				3.C	Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe.	
				7.E	Electrical distribution system is improperly installed or maintained in accordance with applicable state and local codes and rules.	
				3.F	Service building not provided within 500 feet of all sites.	
				3.A.1	Hot and cold water not provided.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				5.A.1	Garbage and rubbish containers are not provided with tight-fitting lids.	
				6.A	Grounds, buildings and structures not maintained free of insect/rodent harborage/infestation and/or methods for control are not compliant with federal or state rules.	
SKYDIVE NEW ENGLAND	NEWOWNER	2021-06-15	No	3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
SKYDIVE NEW ENGLAND	REGULAR	2023-09-01	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	