

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|--------------------|------------|------------|-------|------------|--|----------|
| THE ASPINQUID      | REGULAR    | 2019-05-01 | No    |            | No Violations  |          |
| THE ASPINQUID      | REGULAR    | 2019-10-23 | No    |            | No Violations  |          |
| THE ASPINQUID      | REGULAR    | 2023-06-01 | No    | 9-A.(8)    | Lights are not shielded in the laundry areas and the linen storage facilities.   | N        |
| THE ASPINQUID      | REGULAR    | 2023-06-01 | No    | 5.B.2      | Flow meter not installed and/or is not accurate.   | N        |
|                    |            |            |       | 6.G.1      | Valves not tagged with metal or rigid plastic tags.  | N        |
|                    |            |            |       | 6.C.8      | The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser. | C        |