

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
THE ASPINQUID	REGULAR	2019-05-01	No		No Violations	
THE ASPINQUID	REGULAR	2019-10-23	No		No Violations	
THE ASPINQUID	REGULAR	2023-06-01	No	9-A.(8)	Lights are not shielded in the laundry areas and the linen storage facilities.	N
THE ASPINQUID	REGULAR	2023-06-01	No	5.B.2	Flow meter not installed and/or is not accurate.	N
				6.G.1	Valves not tagged with metal or rigid plastic tags.	N
				6.C.8	The edges of steps, ledges or seats do not have a 4-inch stripe of contrasting color. Stripe should be 2 inches on the thread and 2 inches on the riser.	C