

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
NORSEMAN RESORT	REGULAR	2019-05-01	No	6-301.14	Hand wash signage not provided for employee hand sink or lavatory.	N
				5-205.11.(A)	Hand wash facility not accessible.	N
				6-201.16	Wall and ceiling coverings are not easily cleanable.	N
NORSEMAN RESORT	REGULAR	2019-05-01	No		No Violations	
NORSEMAN RESORT	REGULAR	2023-06-05	No	5-202.12	Hand washing facility not properly equipped/installed with hot water of at least 100 F.	N
				3-602.11.(C). (D)	Bulk food not properly labeled.	N
NORSEMAN RESORT	REGULAR	2023-06-05	No	2-A.(3)	Where only natural ventilation is provided, outside openings are not adequately screened.	N