

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
NE'RE BEACH FAMILY CAMPGROUND	REGULAR	2019-09-26	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				3.E	Individual sewer risers not properly constructed / located / capped.	
				3.C	Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe.	
NE'RE BEACH FAMILY CAMPGROUND	REGULAR	2021-07-21	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	