

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WALTON ELEMENTARY SCHOOL	REGULAR	2018-10-09	No		No Violations	
WALTON ELEMENTARY SCHOOL	REGULAR	2019-10-29	No		No Violations	
WALTON ELEMENTARY SCHOOL	REGULAR	2023-06-12	No	5-203.14	Backflow prevention device not installed when required.	C
				6-501.16	Mops are not being properly stored.	N
WALTON ELEMENTARY SCHOOL	REGULAR	2023-12-14	No	5-202.14	Backflow prevention device does not meet the design standard.	C