

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|--------------------------|------------|------------|-------|------------|---|----------|
| WALTON ELEMENTARY SCHOOL | REGULAR | 2018-10-09 | No | | No Violations | |
| WALTON ELEMENTARY SCHOOL | REGULAR | 2019-10-29 | No | | No Violations | |
| WALTON ELEMENTARY SCHOOL | REGULAR | 2023-06-12 | No | 5-203.14 | Backflow prevention device not installed when required. | C |
| | | | | 6-501.16 | Mops are not being properly stored. | N |
| WALTON ELEMENTARY SCHOOL | REGULAR | 2023-12-14 | No | 5-202.14 | Backflow prevention device does not meet the design standard. | C |