

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LONG LAKE CAMPING AREA	REGULAR	2018-08-14	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
LONG LAKE CAMPING AREA	REGULAR	2020-09-24	No		No Violations	
LONG LAKE CAMPING AREA	REGULAR	2023-08-21	No	1.F	More sites than the approved number.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.F.4	Warm and cold water or a mixture of warm water not provided at all lavatories, sinks, bathtubs, showers and/or cold water not provided to every toilet, urinal, flushing rim sink or laundry fixture.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	