

| Establishment Name     | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation   | Severity |
|------------------------|------------|------------|-------|------------|--|----------|
| LONG LAKE CAMPING AREA | REGULAR    | 2018-08-14 | No    | 3.D        | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. |          |
| LONG LAKE CAMPING AREA | REGULAR    | 2020-09-24 | No    |            | No Violations  |          |
| LONG LAKE CAMPING AREA | REGULAR    | 2023-08-21 | No    | 1.F        | More sites than the approved number.   |          |
|                        |            |            |       | 7.D        | There are no water supply outlets and/or water supply outlets are not backflow protected.  |          |
|                        |            |            |       | 3.F.4      | Warm and cold water or a mixture of warm water not provided at all lavatories, sinks, bathtubs, showers and/or cold water not provided to every toilet, urinal, flushing rim sink or laundry fixture.  |          |
|                        |            |            |       | 3.D        | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. |          |