

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
CROOKED RIVER CAMPGROUND	REGULAR	2019-08-16	No		No Violations	
CROOKED RIVER CAMPGROUND	REGULAR	2023-06-06	No	3.C	Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				5.A.1	Garbage and rubbish containers are not provided with tight-fitting lids.	