

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HEBRON PINES CAMPGROUND	REGULAR	2019-09-04	No	3.F.4	Warm and cold water or a mixture of warm water not provided at all lavatories, sinks, bathtubs, showers and/or cold water not provided to every toilet, urinal, flushing rim sink or laundry fixture.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
HEBRON PINES CAMPGROUND	REGULAR	2022-09-08	No		No Violations	