

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
HIGHLAND LAKE RESORT	REGULAR	2020-07-01	No	9-A.(8)	Lights are not shielded in the laundry areas and the linen storage facilities.	N
				9-A.(6)	No Material Safety Data Sheet available on the premises.	N
				4-A.(1)	Establishment is not in compliance with NFPA 101 Life Safety Code.	C