

| Establishment Name             | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation                                                                                                                                                                                                                                                           | Severity |
|--------------------------------|------------|------------|-------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| BLACK BROOK COVE<br>CAMPGROUND | REGULAR    | 2022-07-08 | No    | 3.A.4      | A current copy of the water analysis is not posted in the park in view of the public and/or the water has not been tested and shown to be satisfactory before the campground opens for the season.                                                                                 |          |
|                                |            |            |       | 7.D        | There are no water supply outlets and/or water supply outlets are not backflow protected.                                                                                                                                                                                          |          |
|                                |            |            |       | 3.D        | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. |          |