

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WINSLOW PARK	REGULAR	2018-07-02	No		No Violations	
WINSLOW PARK	REGULAR	2022-08-17	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	