

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
MOUNTAIN VIEW CAMPGROUND	REGULAR	2019-09-05	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.F.1	Inadequate number of facilities provided.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
MOUNTAIN VIEW CAMPGROUND	REGULAR	2022-07-21	No	7.G	Plumbing is unacceptable.	
				3.B.2	Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface.	