

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
LOONS HAVEN FAMILY CAMPGROUND	REGULAR	2019-10-15	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
LOONS HAVEN FAMILY CAMPGROUND	REGULAR	2023-06-06	No	6-301.14	Hand wash signage not provided for employee hand sink or lavatory.	N
				4-302.14	No chemical test kit available.	N
LOONS HAVEN FAMILY CAMPGROUND	REGULAR	2023-06-06	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	