

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BRANDY POND PARK INC	REGULAR	2019-09-05	No	3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.F.4	Warm and cold water or a mixture of warm water not provided at all lavatories, sinks, bathtubs, showers and/or cold water not provided to every toilet, urinal, flushing rim sink or laundry fixture.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
BRANDY POND CAMPGROUND	NEWOWNER	2023-05-10	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				5.A.1	Garbage and rubbish containers are not provided with tight-fitting lids.	