

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|--------------------|------------|------------|-------|------------|---|----------|
| PALMYRA CAMPGROUND | REGULAR | 2018-09-18 | No | 7.D | There are no water supply outlets and/or water supply outlets are not backflow protected. | |