

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
WILDERNESS EDGE CAMPGROUND	REGULAR	2018-08-13	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				7.G	Plumbing is unacceptable.	
WILDERNESS EDGE CAMPGROUND	REGULAR	2021-07-01	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
WILDERNESS EDGE CAMPGROUND	NEWOWNER	2023-05-18	No	7.D.1	Individual water services are improperly located, designed, protected, or sized.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				6.A.3	Exterior openings in or beneath any structure are not appropriately screened with wire mesh or other suitable materials.	