

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
COHILLS INN	REGULAR	2018-07-12	No	5-202.14	Backflow prevention device does not meet the design standard.	C
COHILLS INN	REGULAR	2018-07-12	No	9-A.(6)	No Material Safety Data Sheet available on the premises.	N
COHILLS INN	REGULAR	2022-07-14	No		No Violations	
COHILLS INN	REGULAR	2022-07-14	No	9-A.(6)	No Material Safety Data Sheet available on the premises.	N
				4-A.(1)	Establishment is not in compliance with NFPA 101 Life Safety Code.	C