

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
FIDDLEHEAD OUTDOORS	REGULAR	2021-07-27	No	3.A.4	A current copy of the water analysis is not posted in the park in view of the public and/or the water has not been tested and shown to be satisfactory before the campground opens for the season.	
				3.B	Unacceptable sewage disposal system.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	
				3.F.6	The building is not free of objectionable odors.	
				3.F.1	Inadequate number of facilities provided.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
				9.A	Privies are not constructed to be fly tight and/or properly ventilated.	
				9.A.5	Privy doors are not self-closing.	
				9.A.4	There are odors and unsightly conditions.	
				9.A.3	Excreta is accessible to flies and animals.	
				9.A.2	Privy has contaminated the surface soil.	
				3.G	Inadequate number of privies.	
				6.A.1	Campground is not maintained free from accumulations of debris that may provide insect/rodent harborage and/or breeding places for flies, mosquitoes and other pests.	
				5.A.1	Garbage and rubbish containers are not provided with tight-fitting lids.	
FIDDLEHEAD OUTDOORS	REGULAR	2022-09-06	No	1.A	Operating without a license.	