

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ON THE SACO FAMILY CAMPGROUND	REGULAR	2019-10-08	No	3.C	Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
ON THE SACO FAMILY CAMPGROUND	REGULAR	2023-06-08	No	3.C	Materials used for sewer connections are not semi-rigid, corrosion-resistant, non-absorbent, durable and water tight and/or sewer connections for seasonal campers not made with rigid pipe.	
				3.F.5	The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair.	