

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SLEEPING BEAR CAMPGROUND & CABINS	REGULAR	2018-08-20	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.D.1	Sanitary stations not properly located and separated by at least 50 feet from all sites.	
SLEEPING BEAR CAMPGROUND & CABINS	REGULAR	2021-08-17	No	8.A.4	Plans submitted did not include specifications of the proposed park or area showing the number and location of RV and tenting sites.	
				3.A.1	Hot and cold water not provided.	