

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
RIVERBEND CAMPGROUND	NEWOWNER	2023-04-12	No	3.A.4	A current copy of the water analysis is not posted in the park in view of the public and/or the water has not been tested and shown to be satisfactory before the campground opens for the season.	
				7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.F	Service building not provided within 500 feet of all sites.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	