

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
BOATMANS CAMPGROUND	REGULAR	2023-07-13	No	2.B	Register does not contain required signature and information.	
				3.D.1	Sanitary stations not properly located and separated by at least 50 feet from all sites.	
				6.B	Openings to the outer air are not effectively protected against the entrance of flies and other flying insects by the use of self-closing doors, closed windows and screening.	
				6.A.3	Exterior openings in or beneath any structure are not appropriately screened with wire mesh or other suitable materials.	