

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|-------------------------------------|------------|------------|-------|------------|--|----------|
| FRYEBUG AGRICULTURE FAIR GROUNDS | REGULAR | 2019-10-02 | No | 3.B.2 | Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface. | |
| | | | | 3.D | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. | |
| FRYEBUG AGRICULTURE FAIR GROUNDS | REGULAR | 2022-10-05 | No | 3.B.2 | Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface. | |
| | | | | 3.D | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. | |