

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
ST GREGORY CAMPGROUND	REGULAR	2019-09-17	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
ST GREGORY CAMPGROUND	REGULAR	2022-07-14	No		No Violations	