

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
PISCATAQUIS VALLEY FAIR CAMPGROUND	REGULAR	2018-08-24	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.B.2	Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface.	
PISCATAQUIS VALLEY FAIR CAMPGROUND	REGULAR	2023-08-24	No	7.D	There are no water supply outlets and/or water supply outlets are not backflow protected.	
				3.B.2	Liquid waste is not being discharged into a suitable container and/or is being discharged onto the ground surface.	
				3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	