

Establishment Name	Insp. Type	Insp. Date	Fail?	Rule Cited	Description of Violation	Severity
SKOWHEGAN STATE AGRIC/FAIR CAMPGROUND	REGULAR	2019-08-08	No	3.D	Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer.	
SKOWHEGAN STATE AGRIC/FAIR CAMPGROUND	REGULAR	2023-08-10	No		No Violations	