

| Establishment Name | Insp. Type | Insp. Date | Fail? | Rule Cited | Description of Violation | Severity |
|---------------------|------------|------------|-------|------------|--|----------|
| OXFORD FAIR GROUNDS | REGULAR | 2019-09-12 | No | 10.A | Wastewater being disposed of on the ground at a temporary campground. | |
| | | | | 3.F.5 | The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair. | |
| | | | | 3.D | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. | |
| OXFORD FAIR GROUNDS | REGULAR | 2022-09-15 | No | 7.D | There are no water supply outlets and/or water supply outlets are not backflow protected. | |
| | | | | 3.F.4 | Warm and cold water or a mixture of warm water not provided at all lavatories, sinks, bathtubs, showers and/or cold water not provided to every toilet, urinal, flushing rim sink or laundry fixture. | |
| | | | | 3.F.5 | The floors, walls and ceiling of the sanitary building are not clean and in good repair and/or the toilets, lavatories and showers are not cleaned and disinfected daily and/or maintained in good repair. | |
| | | | | 3.D | Dump station not provided, properly constructed, provided with suitable hinged cover and/or screw cap, provided with a water outlet posted with a sign that water from this outlet is not for drinking water purposes and/or not protected with an anti-siphon backflow preventer. | |